



STATE OF CONNECTICUT  
DEPARTMENT OF ENVIRONMENTAL PROTECTION



November 3, 1987

Mr. John Fleming  
AVCO Lycoming Division  
550 S. Main Street  
Stratford, Connecticut 06497



Dear Mr. Fleming:

I have reviewed your submission of October 15, 1987 which included three pages from the "Lagoon Cleanup Program for AVCO Lycoming Division, Stratford, CT" prepared by VFL Technology Corp.

It is apparent that the addition of the extra quantity of filtrate from the lagoon sludge dewatering project to the treatment system, would not cause an exceedance of the design flow of the treatment system. For a period of approximately three months however, the average daily flow allowed in NPDES permit No. CT0002984 may be exceeded.

Provided AVCO meets all the pollutant limitations in their permit, the Department does not object to this higher flow for the short period. The additional flow will still be well below the design capability (400 gpm) of the treatment system which is noted in the permit. In addition, this project is being accomplished to prevent further contamination of groundwaters at your facility. Please keep me informed of the cleanup progress.

Sincerely yours,

Richard D. Mason  
Principal Sanitary Engineer  
Water Compliance Unit

RDM:clf

cc: HMMU-Ken Feathers

Phone:

165 Capitol Avenue • Hartford, Connecticut 06106

An Equal Opportunity Employer

200.1e

SAEP\_01.01\_0608\_a