

# **TEXTRON** Lycoming

**Stratford Division**  
Textron Lycoming /  
Subsidiary of Textron Inc

550 Main Street  
Stratford, CT 06497-7593  
USA  
Tel 203/385-2000  
Fax 203/385-3122

April 22, 1992

DMR Processing/Room 1  
DEP/Water Compliance  
122 Washington Street  
Hartford, CT 06106

RE: DMR Permit Number CT00002984

Dear Sir:

Enclosed is the completed Discharge Monitoring Report (DMR) for the Textron Lycoming Stratford, Connecticut plant for the month of March 1992.

During the month of March 1992, three of the pump houses experienced emergency abort discharges during two separate rain events. Three of the discharges were above the maximum or monthly average for total oil & grease and four of the discharges were above the maximum limit for total suspended solids. The concerns with the abort discharges are being addressed under an Administrative Order from the Environmental Protection Agency.

Discharge 008 failed the first quarter chronic aquatic toxicity test for the Mysidopsis bahia. The associated chemical analysis failed to identify a specific cause for the toxicity. In response to this and previous toxicity concerns, a toxicity investigation is being conducted in an attempt to determine the cause(s) of the toxicity.



J. Runstadler  
Environmental Engineer