

# **TEXTRON** Lycoming

Stratford Division  
Textron Lycoming/  
Subsidiary of Textron Inc.

550 Main Street  
Stratford, CT 06497  
203/385-2000

September 23, 1992

DMR Processing/Room 1  
DEP/Water Compliance  
122 Washington Street  
Hartford, CT 06106

---

RE: DMR Permit Number CT00002984 .

Dear Sir:

Enclosed is the completed Discharge Monitoring Report (DMR) for the Textron Lycoming Stratford, Connecticut plant for the month of August 1992.

During the month of August 1992, all six (6) pump houses experienced emergency abort discharges during high rain events. A number of the discharges exceeded permitted limits for total suspended solids and oil & grease. These high levels of suspended solids and oil & grease are currently being addressed under an Administrative Order from the Environmental Protection Agency. An engineering plan to correct the problem has been submitted to the EPA and Connecticut DEP and efforts are under way to implement and evaluate corrective action procedures.

During shutdown (the first week of August), the Chemical Waste Treatment Plant was offline for routine maintenance. During this period the plant did not discharge water.

Sincerely,



James P. Runstadler  
Mgr. Environmental Svcs.

JPR/fc  
attachments