

March 1, 1996

Helen Robbins
State of Connecticut
Department of Environmental Protection
Underground Tank Enforcement Program
79 Elm Street
Hartford, Connecticut 06106


Dear Ms. Robbins:

The following is a final report on the closure of the last two underground storage tanks at the Stratford Army Engine Plant, site I.D. 138-8054.

Two, 3000 gallon UST's, previously utilized for the storage of gasoline, were excavated and removed on December 20, 1995 in compliance with NFPA 30 and Section 22a-449(d)-107 of the state regulations for UST management. These tanks were installed in March, 1990. Upon removal of the tanks from the ground, the excavation and the soil removed showed no visual signs of contamination nor were any hydrocarbon odors detected. The tanks and associated piping showed no signs of degradation or corrosion.

Two soil samples were taken down hydraulic gradient from the tanks at ground water level. The laboratory analysis attached indicates extremely low petroleum hydrocarbon levels. If there are any questions please contact me at (203)385-1683.

Sincerely,


Scott Jacobs
Environmental Engineer

MILFORD MATERIALS TESTING LABORATORY, INC.

655 Plains Rd. • Milford, Connecticut 06460

Phone (203) 877-3163 Fax (203) 876-8162

1-800-352-1399

Mail to PO Box 493
Milford, Conn 06460

January 23, 1996
Test M65320

TO: AlliedSignal
550 South Main St.
Stratford, CT 06497

FROM: Dominic Mastrone

ATT: Mr. Scott Jacob, Dept. 1M

RE: Exam of four soil samples & one concrete sample, POH350182,
Dated 1/18/96, Rec'd. 1/19/96

TEST

RESULTS

ID 011896	-1	-2	-3	-4	-5
Total Petroleum Hydrocarbon	154.0	176.0	188.0	6.0	2.0 ppm

Samples ID 011896-1, 2 & 3 were analyzed per EPA Method 8010. The results are on the following pages.

ID NO. 011896-4, 011896-5 - SOIL FROM BLDG 10 UST
REMOVAL PROJECT

Dominic Mastrone