

TEXTRON Lycoming

Stratford Division
Textron Lycoming /
Subsidiary of Textron Inc.

550 Main Street
Stratford, CT 06497
203/385-2000

January 28, 1991

State of Connecticut, D. E. P.
Water Compliance Bureau - DMR
165 Capitol Avenue
Hartford CT 06106

RE: December DMR - Textron Lycoming

Gentlemen:

For the enclosed DMR (December 1990) cyanide, both total and amenable were high for discharge 008A and total cyanide was high for discharge 008. These high monthly average values were due to the cyanide treatment facility (008A) having a breakdown on the day samples were taken (December 18). Copper was high at the same time due to complexing with the cyanide.

Repairs were made to that facility later that week and cyanide has not been a problem in the weekly samples since that time. A corrective action plan has been developed by the waste treatment operations supervisor to prevent future occurrences.

Sincerely yours,



Michael P. Nosenzo
Environmental Engineer

MPN/ssc
MPN1128

cc: P. Bonitatebus
Q. Carloni
R. Dennis
J. Fleming
R. Kelley
J. Morrell