

TEXTRON Lycoming

Stratford Division
Textron Lycoming/
Subsidiary of Textron Inc.

550 Main Street
Stratford, CT 06497
203/385-2000

February 26, 1993

DMR Processing/Room 1
DEP/Water Compliance
122 Washington Street
Hartford, CT 06106

RE: DMR Permit Number CT00002984


Dear Sir:

Enclosed is the completed Discharge Monitoring Report (DMR) for the Textron Lycoming Stratford, Connecticut plant for the month of January 1993.

During the month of January 1993, all four (4) pump houses experienced emergency abort discharges due to a heavy rain storm on January 5, 1993. A couple of the discharges exceeded permitted limits for total suspended solids and oil & grease. These high levels of suspended solids and oil & grease are currently being addressed under an Administrative Order from the Environmental Protection Agency. An Engineering Plan to correct the problem has been submitted to the EPA and Connecticut DEP and efforts are under way to implement corrective action procedures.

Aquatic toxicity monitoring was performed for the month of January, 1993 because of a chronic toxicity problem in the month of December 1992 on the 008 discharge from the Chemical Wastewater Treatment Plant. The aquatic toxicity test for January 1993 passed both acute and chronic toxicity.

Sincerely,
Textron Lycoming



James P. Runstadler
Manager Environmental Services

Enclosure
JPR/vzb