



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION




TEXTRON LYCOMING
550 SOUTH MAIN ST.
STRATFORD CT 06497

RE: TEXTRON LYCOMING
STRATFORD
CT0002984 MAJOR
APRIL, MAY, JUNE

DEAR PERMITTEE:

A REVIEW OF OUR RECORDS OF MONITORING DATA SUBMITTED IN COMPLIANCE WITH YOUR NPDES PERMIT SHOWS THE FOLLOWING VIOLATIONS :



SAMPLE MONTH	DISCH	AVERAGE PERMIT LIMIT	MONTHLY RESULT	UNIT	PARAMETER
9105	001	20.000	56.400	MG/L	TOTAL SUSPENDED SOLIDS
9106	001	20.000	67.500	MG/L	TOTAL SUSPENDED SOLIDS
9105	003	20.000	41.400	MG/L	TOTAL SUSPENDED SOLIDS
9106	003	20.000	96.000	MG/L	TOTAL SUSPENDED SOLIDS
9104	006	20.000	35.000	MG/L	TOTAL SUSPENDED SOLIDS
9105	006	20.000	92.000	MG/L	TOTAL SUSPENDED SOLIDS
9106	006	20.000	47.500	MG/L	TOTAL SUSPENDED SOLIDS

PLEASE SUBMIT A REPORT TO THIS OFFICE WITHIN 30 DAYS OF THE DATE OF THIS LETTER DESCRIBING THE CAUSE(S) OF THE VIOLATION AND CORRECTIVE MEASURES TAKEN OR PROPOSED. FORMAL ENFORCEMENT ACTION MAY BE TAKEN FOR THESE VIOLATIONS. YOUR PERMIT REQUIRES YOU TO SUBMIT EXPLANATIONS OF VIOLATIONS WITH YOUR DMR. FAILURE TO DO SO CONSTITUTES A SEPERATE VIOLATION OF YOUR PERMIT. IF YOU HAVE ANY QUESTIONS, PLEASE CONTACT THE ENGINEER LISTED BELOW.

THE ORIGINAL REPOSEN LETTER SHOULD BE SENT TO:

CARRIE CORRELL
DEP/BUREAU OF WATER MANAGEMENT
122 WASHINGTON STREET
HARTFORD, CT 06106

PHONE: 566-5903

COPIES OF THE RESPONSE LETTER SHOULD ALSO BE SENT TO:

DATA MANAGEMENT
DEP/BUREAU OF WATER MANAGEMENT
122 WASHINGTON STREET
HARTFORD, CT 06106

MR. MICHAEL FEDAK, ENVIRONMENTAL ENGINEER
USEPA - WATER MANAGEMENT DIVISION
JFK BUILDING - ROOM 2103 (WCC)
BOSTON, MA 02203
I3 138 - 023