



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



April 6, 1987

Avco Lycoming Textron
550 South Main Street
Stratford, Connecticut 06497



Attention: Peter Bonitatebus

Enclosed please find a copy of a Compliance Inspection Report dated March 30 1986 Re: CT0002984. This form is intended to gather information and support data fundamental to the NPDES and State Permit Compliance program.

Please respond to the reviewer in writing within 10 days in reference to sections C & D on comments receiving an unsatisfactory review, if applicable. Send to Department of Environmental Protection, Water Compliance Unit, 122 Washington Street, Hartford, CT 06106.

Richard Mason (EF)

Department of Environmental Protection
Water Compliance Unit
122 Washington Street
Hartford, CT 06106

enclosures

Phone:

165 Capitol Avenue • Hartford, Connecticut 06106

An Equal Opportunity Employer

200.1e
SAEP_01.11_0530_a



NPDES Compliance Inspection Report

Form Approved
OMB No 2040-0003
Approval Expires 7-31-85

Section A: National Data System Coding

Transaction Code: 1N 25
 NPDES: 3CT10101029181411
 yr/mo/day: 12/8/87
 Inspection Type: 18S
 Inspector: 19S
 Fac Type: 202

Remarks

Reserved: 67 [] [] [] 69
 Facility Evaluation Rating: 703
 BI: 71N
 QA: 72N
 Reserved: 73 [] [] [] 74 [] [] [] 75 [] [] [] 80

Section B: Facility Data

Name and Location of Facility Inspected Avco Lycoming Textron 550 South Main Street Stratford, CT, 06497		Entry Time <input checked="" type="checkbox"/> AM <input type="checkbox"/> PM	Permit Effective Date 29 July 1985
		Exit Time/Date 3-30-87	Permit Expiration Date 29 July 1990
Name(s) of On-Site Representative(s) Mike Nosenzo	Title(s) Environmental Engineer	Phone No(s) 203 385-3964	
Name, Address of Responsible Official Peter Bonitatebus	Title Manager Engineering	Contacted <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Phone No.			

Section C: Areas Evaluated During Inspection

(S = Satisfactory, M = Marginal, U = Unsatisfactory, N = Not Evaluated)

S	Permit	M	Flow Measurement	N	Pretreatment		Operations & Maintenance
S	Records/Reports	S	Laboratory	N	Compliance Schedules		Sludge Disposal
S	Facility Site Review	S	Effluent/Receiving Waters	S	Self-Monitoring Program	N	Other: _____

Section D: Summary of Findings/Comments (Attach additional sheets if necessary)

Permit - Name & ownership change from Avco Corp. to Avco Lycoming Textron, Manufacturing and wastewater has not changed. New wastewater treatment system is near completion.

Flow Measurement - Final effluent flow meter not operating correctly, company is using an influent meter to obtain final flow. New system will have a new flow measuring system.

Name(s) and Signature(s) of Inspector(s) Edward Furger	Agency/Office/Telephone CT, DEP Water Compliance	Date 4-06-87
---	---	-----------------

Signature of Reviewer Richard Mason	Agency/Office CT DEP 566-7139	Date 4-16-87
--	----------------------------------	-----------------

Regulatory Office Use Only

Action Taken	Date	Compliance Status <input type="checkbox"/> Noncompliance <input type="checkbox"/> Compliance
--------------	------	--