



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



PUBLIC NOTICE OF INTENT TO APPROVE
A STATE PERMIT
FOR THE FOLLOWING NEW DISCHARGE INTO THE WATERS OF THE STATE OF CONNECTICUT

Name, Mailing Address and Location Address of Applicant

Avco Lycoming Stratford Division
Avco Corporation
550 South Main Street
Stratford, Conn. 06497

Name, Mailing Address and Location Address of Facility

Avco Lycoming Stratford Division
Avco Corporation
125 Access Road
Stratford, Conn. 06497

Application Permit Number

86-451

Receiving Waters Name and Location

Town of Stratford Sewerage System

Nature of Activity Generating Discharge

Discharge parts cleaning wastewater at an average flow of 7,500 gallons per day.

Type of Treatment

Oil and grease separation and neutralization of wastewaters.

Effluent Limitations

This permit contains effluent limitations consistent with Section 22a-430-4(1) of the Regulations of Connecticut State Agencies.

Notice is hereby given that the applicant named above has applied to the Commissioner of Environmental Protection for a permit to initiate such discharge. The Commissioner of Environmental Protection is authorized to approve or deny such permits pursuant to Section 402(b) of the Federal Water Pollution Control Act, as amended, 33 USC 1251, et. seq., Section 1421 of the Federal Safe Drinking Water Act 42 USC et. seq. and Section 22a-430 of the Connecticut General Statutes as amended (hereinafter "the C.G.S.").

Phone:

165 Capitol Avenue • Hartford, Connecticut 06106

An Equal Opportunity Employer

200.1e
SAEP_07.10_0504_a


On the basis of preliminary review by members of the department staff in accordance with applicable federal and state law the Commissioner has made the tentative determination that the proposed system to treat the discharge will protect the waters of the state from pollution, and the Commissioner proposes to require the applicant to submit plans and specifications for the treatment system and such additional information as the Commissioner deems necessary to ensure the protection of the waters of the state from pollution. If such plans are approved by the Commissioner and the treatment system constructed in full compliance with the approval, the Commissioner proposes to issue a permit for this discharge.

The proposed permit issued by the Commissioner will require that all wastes be treated to meet the applicable effluent limitations.

The Department of Environmental Protection has made a preliminary determination that the activity proposed in this application is within the coastal boundary defined in Section 22a-94 of the C.G.S. Pursuant to Section 22a-98 of the C.G.S. the activity proposed in this application must be consistent with all applicable coastal policies in Section 22a-92 of the C.G.S. as well as other lawful policies, standards and criteria. Applicants must demonstrate the consistency of the proposed activity with applicable coastal policies.

Interested persons who wish to obtain more information including copies of the application, proposed permit, fact sheet, comments received, and other information may do so by contacting Marc Otfinoski, at 122 Washington Street, Hartford, Connecticut 06106, between 8:30 a.m. and 4:30 p.m., Monday through Friday at (203)566-5903.

Prior to making a decision to approve or deny any application, the Commissioner shall consider comments from interested persons which are received within 30 days of this public notice. If the Commissioner decides that the public interest will best be served thereby, or upon receipt of a petition signed by at least 25 persons, a public hearing will be held on this application. Notice of any public hearing shall be published at least 30 days prior to the hearing.



Richard J. Barlow
Director
Water Compliance Unit

Dated: May 1, 1987